

Annexure C

Office of the Assistant Engineer
Public Health Engg. Sub Division Jabalpur (M.P.)

No. - 337

-Dated:- 08/05/2026

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is Certified that an inspection team headed by **Shri Deepak Khare**

From **Assistant Engineer Public Health Engg. Sub Division Jabalpur**

Inspected **Doon International School Nagpur Road Opp. Tata Motors**

Manegaon, Jabalpur On Dt. **07/05/2026** (dt. Of Inspection) and on the basis of Water test report

(Attached) bearing no. **Report No. 07** Dated **21/04/2026** of **District Water Testing**

Laboratory Public Health Engg. Division Jabalpur (M.P.) (PHED Lab)

Certified that the **Doon International School Nagpur Road Opp.**

Tata Motors Manegaon, Jabalpur has safe drinking water facilities for the student and

members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the central/State/U.T. Govt.

This certificate is valid till **Six Months only**.

Signature with Seal :-

Name :-

Designation :-

Name & Address of Office :-

Assistant Engineer

P.H.E. Sub-Division
(Deepak Khare)

Assistant Engineer

Public Health Engg. Sub Division
Jabalpur (M.P.)

To,

Doon International School,

Nagpur Road Opp. Tata Motors,

Manegaon, Jabalpur (M.P.)

(Name & Address of the Institution)



Vandana ..
Principal
Doon International School
Jabalpur (M.P.)

DISTRICT WATER TESTING LABORATORY
Office of the Executive Engineer, Public Health Engg. Division Jabalpur M.P.
WATER TESTING REPORT

Report No. - 07	Date	21/04/2026	UID No. JBP/
Ref. NO. DISJBP/ADM/GEN	Date	15/04/2026	Village & Location
To,		1- Doon International School Nagpur Road Opp. Tata Motors Manegaon, Jabalpur Campus	
Sample Collected by		2- water source - Tubewell water	
Date of collection		15/04/2026	
Source		Tubewell	
Date of receipt		15/04/2026	
Date of Testing		15/04/2026	
Test conducted by		3- Kavita Rajak (Chemist)	

As per BIS 10500:2012 Reaffirmed in feb 2021 For Drinking Water

Sl no.	Characteristic	Unit	Acceptable	Cause for rejection	TEST RESULT	
					1	2

PHYSICAL-TEST

1	Turbidity	NTU	1.0	5.0	1.2	
2	Colour	Pt. Cobalt	1.0	25.0	2	
3	Taste & Odour	Agreeable	Agreeable	Agreeable	Agreeable	

CHEMICAL-TEST

4	pH	...	6.5 to 8.5	6.5 to 8.5	7.67	
5	Conductivity	M. Mohs/cm	..	..	125	
6	Alkalinity	mg/l	200	600	90	
7	Chloride (As cl)	mg/l	250	1000	25	
8	Nitrates	mg/l	45	45	0.0	
9	Total Hardness (As CaCO ₃)	mg/l	200	600	150	
10	Calcium (As Ca)	mg/l	75	200	16.0	
11	Magnesium (As Mg)	mg/l	30	100	12.0	
12	Total dissolved solid	mg/l	500	2000	80	
13	Iron (As Fe)	mg/l	1.00	1.0	0.12	
14	Manganese (As Mn)	mg/l	0.10	0.30	0.0	
15	Fluoride (As F)	mg/l	1.00	1.50	0.08	
16	Sulphates As SO ₄	mg/l	200	400	0.36	
17	Residual Chlorine	mg/l	0.20	1.0	0	

BACTERIOLOGICAL-TEST

18	Total Coliform	per 100ml	0	..	0	
19	E Coli or Thermo tolerant coliforms	per 100ml	0	..	0	

Remark:-

Note:- 1. As above result compared with BIS 10500:2012

2. Samples are not collected by us.

3. Not to be produced at court of law.

4. We do not take any responsibility for deviation in test result due to wrong collection of sample

Vandana ..

Principal
Doon International School
Jabalpur (M.P.)

Kavita Rajak
21/04/2026
Chemist
District Laboratory
R.M.E. Dn. Jabalpur

